



Industry Division

CERTIFICATE OF INSPECTION NO.: TPI13084-2

Issuing Center : Taipei Taiwan

Supplier/Address : Kevin Steel Corporation
14F-3, No.57, Daya Rd., Taichung,
Taiwan

The undersigned, B.H. Juang acting with the scope of General Condition of the industrial Branch of Bureau Veritas, certifies that the supplies

Type Designation : MD-82
Type of valve: : 2PCs Flanged End Ball Valve (Full Bore)
Pressure rating: : Class #150
Nominal size: : 6 inch x 1 piece
Material
(a) Body : ASTM A216 WCB
(b) Bonnet : ASTM A216 WCB
(c) Seat : RTFE

Inspected in Lung-Tan, Taiwan

On 6th Aug. 2013

Has been upon request of : Kevin Steel Corporation

Intended for : Kevin Steel Corporation

Inspected in conformity with the applicable requirements of the valve fire test per API 607, SIXTH EDITION and contractual requirements governing the mission entrusted to Bureau Veritas.

Made In Taipei, Taiwan on 20th Aug. 2013

Signature B.H. Juang
Surveyor to Bureau Veritas



Addition qualification of other valves, covered by the valves tests according API standard 607 6th Editions, 2010.

The qualification of ANSI Class : Class 150; 300 (PN10; 16; 25; 40)

The qualification of Size : 6"; 8"; 10"; 12"

Manufacturer : Kevin Steel Corporation

Particular mention : The test result of valve fire test is passed
Test report of valve fire test attached