



Industry Division

CERTIFICATE OF INSPECTION NO.: TPI14039 R
Issuing Center : Taipei Taiwan
Supplier/Address : Kevin Steel Corporation
14F-3, No. 89, Sec. 1, Zhong qing
Rd., North Dist., Taichung City,
Taiwan (R.O.C.)

The undersigned, B.H. Juang acting with the scope of General Condition of the industrial Branch of Bureau Veritas, certifies that the supplies

Type Designation : V-255FS
Type of valve: : 3PCs Screwed End Ball Valve (Full Bore)
Pressure rating: : Class 600
Nominal size: : 2 inch x 1 piece
Material
(a) Body : ASTM A216 WCB
(b) Ball : ASTM A351 CF8M
(c) Seat : RTFE

Inspected in Lung-Tan, Taiwan On 23rd Jun. 2014

Has been upon request of : Kevin Steel Corporation

Intended for : Kevin Steel Corporation

Inspected in conformity with the applicable requirements of the valve fire test per API Standard 607, Sixth Edition, 2010 and contractual requirements governing the mission entrusted to Bureau Veritas.

Made In Taipei, Taiwan on 15 Oct. 2014

Signature B.H. Juang
Surveyor to Bureau Veritas



Addition qualification of other valves, covered by the valves tests according API Standard 607, Sixth Edition, 2010.

The qualification of ANSI Class : Class 600; 800; 900

The qualification of Size : 2" and below; 2 1/2"; 3" ; 4"

Manufacturer : Kevin Steel Corporation

Particular mention : The test result of valve fire test is passed
Test report of valve fire test attached